



Rough Framing Inspection Checklist – Wood Roof Trusses

DRAFT

Address:		Contractor:		Permit #	
The following checklist is not all-inclusive. Other code related requirements may be included in this inspection.					
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R 802.10.1 & R802.10.2—Review truss design and placement drawings.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.10.1 #4.5 & #9—Verify multi-ply girder connections and provide studs under each ply to the foundation, when supported by a framed wall.		
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.10.1 #1 & #4—Confirm correct loads and spacing.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.10.1#9—Verify structural connections—clips, hangers and hold downs and installed per manufacturer installation instructions (fasteners).		
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	BSCI- B6- Verify proper gable end bracing.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R 802.10.1 #12 & 802.10. 3, BCSI B3—Verify locations of all required bracing.		
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Table R502.5(1) & 802.10 #6—verify header and beam sizes.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.10.4—Check for truss damage and repairs.		
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R301.1 & 802.10.4.5—Verify that the point loads go the foundation.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>			
OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	R802.10 #3—Verify “area” (width) of the bearing locations.	OK Yes No n/a <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>			
Notes:					

Date		Inspector	
------	--	-----------	--